

BOARD OF COMMISSIONERS

March 05, 2018 7:00 PM This agenda is only a tentative schedule of matters the Commissioners may address at their meeting and all items found on it may be deleted, amended or deferred. The Commissioners may also, in their absolute discretion, consider matters not shown on this agenda.

Special accommodations for the disabled who attend public meetings can be made by contacting the Clerk to the Board 24 hours in advance at 252-338-6363, Ext. 100.

Please turn Cell Phone ringers off during the meeting.

Agenda

Camden County Board of Commissioners SCWSD - Regular Meeting March 05, 2018 7:00 PM Historic Courtroom, Courthouse Complex

<u>1.</u> CALL TO ORDER

ITEM 2. **PRESENTATIONS** (For discussion and possible action)

ITEM 3. <u>PUBLIC COMMENTS</u>

It is requested that comments be limited to (2-3) minutes. The length and number of comments may be limited upon the Chairman's discretion due to scheduling and other issues.

ITEM 4. <u>CONSIDERATION OF THE AGENDA</u>

- ITEM 5. <u>OLD BUSINESS</u> (For discussion and possible action)
- **ITEM 6.** <u>NEW BUSINESS</u> (For discussion and possible action)

A. Monthly Update

- ITEM 7. <u>CONSENT AGENDA</u>
- ITEM 8. <u>INFORMATION</u>
- ITEM 9. <u>OTHER</u>
- ITEM 10. ADJOURN



South Camden Water & Sewer District Board of Directors AGENDA ITEM SUMMARY SHEET

Information

Item Number:	6.A			
Meeting Date:	March 05, 2018			
Submitted By:	David Credle, Public Works Director Public Works Prepared by: David Credle			
Item Title	Monthly Update			
Attachments:	January 2018	(DOCX)		
Summary: Water/Sewer Depa	artment update.			

Recommendation: Approval.

South Camden Water & Sewer Board

Monthly Work Order Statistics Report

Period: January 2018

	Submitted Work Orders	Completed Work Orders	Percentage Completed	Status of Uncompleted Work Orders
Water/Distribution	101	101	100%	0
Sewer/Collection	3	3	100%	0

Locates:

Water Line: 80

Sewer Line: 40

Water & Sewer, same ticket: 2

Public Works Director Notes/Comments: Ten work orders have been reviewed for accuracy.

Treated gallons at the R/O WTP in January, 11,364,260

Average daily water use 366589 gallons/ Current treatment capacity 720000 gallons per day.

South Camden fire hydrants were flushed and checked for proper operation in 2017.

South Camden fire hydrants will be flow tested in the next two years, 2018 and 2019, to be ready for the department's next inspection in 2020.

6.A.a

The treated wastewater lagoon liner, on McPherson Road, has a tear about 135 feet long. The tear was discovered after the last snow storm. We think the ice and heavy winds caused the tear. Staff is working with Anlauf Engineering to discuss repair options and will have Joe Anlauf at the April Commissioners Meeting to explain the repair options. Staff has installed sheet plastic and Geo fabric to stabilize the berm from further damage.

The Noblet High School property was bush hogged in Mid-December, 42.5 ac. at a cost of \$4600.